

Pipe Temp.	Line Type
CW	
HW	
Recirc	
Tempered	•••••
Ball Valve	
Check Valve	
Drain Valve	
Strainer	
Pump	
TS Temperature Switch	
Temperature Indicator	
Thermometer	
Backflow Preventer	
Balancing Valve Circuit Setter	
T&P Relief Valve	
Floor Drain	
	Temp Jr. ing Valve

PVI

Fort Worth, TX 76134

CONQUEST – SINGLE UNIT, MULT

SIDEARM STORAGE TANK
DRWN BY. DATE DWG. NO:

DRWN BY.

DATE 071723 DWG. NO: PV 8854 Page 1 of 1 REV.

- 10. DO NOT EXCEED 160° F STORED WATER TEMPERATURE IN THE SIDEARM TANK.

 11. ENSURE ALL PIPE DIAMETERS ARE SIZED ADEQUATELY TO HANDLE THE FLOW VOLUME (GPM) AT A MAXIMUM WATER VELOCITY OF 6 FEET PER SECOND.
- 12. DURING INITIAL STARTUP OF THE HEATER AND TANK, THE HEATER MAY CYCLE OCCASIONALLY.

9. REFER TO VALVE MANUFACTURER PIPING INSTRUCTIONS.

CONNECTION OF 2", PUMPS SHOULD BE SIZED FOR THE QUANTITY OF HEATERS TIMES UP TO 30 GPM.

7. RECIRC PUMP DETERMINED BY PLUMBING ENGINEER AND MINIMUM FLOW VARIES BY DIGITEMP MODEL.

13. ALL (*) COMPONENTS ARE OPTIONAL FOR INSTALLATION UNLESS OTHERWISE STATED PER LOCAL CODE REQUIREMENTS.

8. N.C. BYPASS PIPING ALLOWS HEATER TO CONTINUE OPERATION WITH THE STORAGE TANK REMOVED FROM THE SYSTEM.

14. THE FOLLOWING COMPONENTS SHALL BE FIELD SOURCED: CHECK VALVES, STRAINERS, BALL VALVES, BALANCING VALVES, PUMPS, TEMPERATURE SENSORS, EXPANSION TANK, BACKFLOW PREVENTER.

6. FOR UNITS WITH RECRIC. CONNECTION OF 1", PUMPS SHOULD BE SIZED FOR THE QUANITY OF HEATERS TIMES UP TO 10 GPM. FOR UNITS WITH RECIRC.