





PIPING GUIDELINE: TWO WATER HEATERS WITH REVERSE RETURN PIPING
NOTE: For TURBOPOWER® 99 water heaters, refer to form PV 6766

	Union
	Isolation Ball Valves
	Check Valve
	T&P Relief Valve (pipe in accordance with local codes, or direct to drain with no valves or restrictions)

Tank fitting location may vary from those shown.

